

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

* * * * *

In the Matter of:

THE APPLICATION OF ROBIE CRISLIP, ROUTE)
201, SITKA, KENTUCKY, TO DEVIATE FROM)
COMMISSION REGULATION 807 KAR 5:026,) CASE NO. 8758
SECTION 6, SUBSECTION 6)

O R D E R

On January 16, 1983, Robie Crislip, Route 201, Sitka, Kentucky, filed a letter with the Commission requesting authority to use 1 1/4 inch plastic pipe in the construction of a service line to his residence from a line of the Kentucky West Virginia Gas Company.

The Commission will treat this letter as an application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 5:026, Section 6, Subsection 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various digging activities and recommended the granting of the requested authority.

The Commission, having considered the application and all evidence of record and being fully advised, is of the opinion and finds that:

1. A hearing to consider the merits of the application will not be necessary.

2. Mr. Crislip should be granted permission to use 1 1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and the entire service line is buried a minimum of 36 inches.

3. The completed service line installation should be inspected by Commission staff prior to the filling of the ditch.

4. Mr. Crislip should notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. The plastic pipe should be installed by persons who qualify under the requirements of 49 CFR 192.285.

6. This service line should be used only to serve one dwelling as required by state law.

7. Mr. Crislip should meet all other requirements of Public Service Commission Regulation 807 KAR 5:026, Section 6, in his installations.


IT IS THEREFORE ORDERED that Robie Crislip be and he hereby is granted authority to deviate from Public Service Commission Regulation 807 KAR 5:026, Section 6, Subsection 6, and to install 1 1/4 inch plastic pipe of an approved type for his service line, said pipe to be buried a minimum of 36 inches.

IT IS FURTHER ORDERED that Robie Crislip shall notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of

Utility Engineering and Services of the Public Service Commission
before service is rendered.

Done at Frankfort, Kentucky, this 1st day of February, 1983.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Secretary